



NOTE:

POSTS TO BE-

- GALVANISED 90 x 90 x 2mm AND A MINIMUM OF 1.5m LONG
- A MINIMUM OF 1.0m ABOVE FSL AND A MINIMUM OF 0.5m SET IN CONCRETE
- CAPPED AND PAINTED MID BLUE (B51 to AS 2700)

MARKERS TO BE-

- 275 x 75 x 1.5mm ALUMINIUM PLATE
- STAMPED WITH ADDITIONAL INFORMATION AS REQUIRED (OFF SET, DEPTH, ANGLE OF BEND) USING A SET OF METAL PUNCH
- FIXED TO EITHER-
 - A STANDARD MARKER POST USING 4 x 8g NON CORROSIVE (OR BLIND RIVETS)
 - OR
 - A CLOSE PERMANENT STRUCTURE (POWER POLE, ETC) USING NON CORROSIVE SCREWS AT A MINIMUM HEIGHT OF 1 METRE

B	PAINT CODE TYPO (from15 to 51)	R.D.	12-10-16	
A	CONCRETE POST TO GALVANIZED POST	R.D.	07-08-12	
MK	DETAILS OF AMENDMENTS	INIT.	DATE	

REDUCTION RATIO

N.T.S.

ALL LEVELS ARE IN METRES
ALL CHAINAGES ARE IN
METRES ALL OTHER
DIMENSIONS ARE IN
MILLIMETRES UNLESS SHOWN
OTHERWISE

DESIGNED: R.D.	FIELD BOOK: NA	ORIGIN OF LEVELS: NA
SURVEYED: NA	LEVEL BOOK: NA	AZIMUTH: NA
DRAWN: R.D.	DATUM: NA	DRAWING FILE: 25350-50a DWG
DATE: AUG 2012	CHECKED: D.B.	REFERENCE FILE: 999 A1 Frame

	DIRECTOR, SHOALHAVEN WATER	DATE
A Group of Shoalhaven City Council	PLANNING & DEVELOPMENT MANAGER	DATE

WATER STANDARD DRAWING
ARRANGEMENT FOR
MARKER POSTS AND
PLATES

FILE NO:	PLAN SIZE: A3	REVISION NO: B
PLAN REFERENCE:	W20855-005	