

Downsize, Disconnect or Nominal Sizing of Water Meter Services

For more information contact
Shoalhaven Water

City Administration Centre

Bridge Road (PO Box 42)
Nowra NSW Australia 2541
P: (02) 4429 3214
F: (02) 4429 3170
water@shoalhaven.nsw.gov.au
www.shoalwater.nsw.gov.au

Policy Number: POL16/92

Adopted: 23/02/2004

Amended: 23/11/2004, 27/06/2006, 27/01/2009, 29/01/2013, 16/05/2017

Minute Number: MIN04.231, MIN06.851, MIN09.67, MIN13.35, MIN17.401

File: 28864E

Review Date: 1/12/2020

1 PURPOSE

The purpose of this Council Policy and Internal Process is to provide guidance to customers on making an application to downsize, upsize, disconnect or nominal sizing of water meter service connections and the process involved.

2 STATEMENT

The introduction of Best Practice Pricing contains as a key element of the pricing structure for the Water and Wastewater Availability Charge, a cost based on the size of the water meter service connection.

Council at its meeting 27th June, 2006 considered it appropriate to provide customers with the option of being able to downsize the water meter service connection in order to reduce the price impact of the availability charges. There may also be a future need to upsize connections which have previously been approved for downsize. Limited costs for application of this initiative will be considered by Council at the level outlined in paragraph 3 - Costs. The downsize of the water meter service connection is not an automatic option and must be considered in light of the need to provide appropriate water supply services to the premises.

2.1 Scope

This policy applies to all service connections including CSO.

2.2 Abbreviations/Acronyms

CSO – Community Service Obligation

DA – Development Application

BCA – Building Code of Australia

2.3 Definitions

Engineer – Person with appropriate qualifications in the Engineering field and eligible for membership with the Institute of Engineers Australia.

Certificate of Compliance – Statement from the Water Supply Authority certifying that all Water and Sewerage requirements for a development have been fully satisfied under the Water Management Act.

Single Dwelling – a property of not more than 1 building eg does not contain dual occupancy, strata or granny flat.

2.4 Related Documentation

- Application for water service connection
- Application for water meter service connection downsize
- Process for handling of requests/processing/assessing applications (refer appendix 1)

2.5 Common Provisions

There are no common provisions relating to this subject.

3 PROVISIONS

Council will consider all applications for the downsize, disconnect or nominal sizing of water meter service connections. Applications must however be:

- Submitted using the applicable application form
- Signed by the property owner or Secretary of the Body Corporate if Strata
- Accompanied by a Consulting Engineers of Hydraulic Report and other supporting documentation as required by Council (the costs incurred in providing the supporting documentation will be at the applicants expense)

The submission of an application and any recommendation contained within the accompanying Consulting or Hydraulics Engineers Report does not place any obligation on Council to approve such. All applications are subject to assessment by Shoalhaven Water and Councils Planning & Development Group. All applications are subject to final determination and approval by the Director Shoalhaven Water or delegate.

The determination and approval by Council of an application and the final nomination of the appropriate size of the water meter service connection will be based on but not necessarily limited to;

- Affect a downsize will have on the quality and quantity of water pressure and flow.
- Development Conditions applicable to the premises.
- The effect of downsize on backflow prevention devices,
- The need to provide adequate function of fire support systems eg hose reel or hydrant etc, and conform with the relevant BCA and NSW Plumbing and drainage codes
- The nature of the premises and likely impact for onsite residents ie units, caravan parks etc, and
- NSW Fire Brigade requirements.

The Engineers report is to address the issues indicated above.

There is no limit to which an application for downsize of water meter service connection can be rendered for assessment. The determination of an appropriate downsize however will be approved based on the request by the customer but also on the requirements of Shoalhaven Water in providing adequate and appropriate water services together with the requirements of any approved Development Application or meeting various compliance requirements.

All applications for water meter service connections will be effective and adjustments undertaken from the issue date of the next water account following the submission of the application subject to the application being completed in all respects and accepted for determination. Availability charges at the higher rate will however continue to be levied until approval is granted. Adjustments to availability charges will be undertaken only once approval is given.

Applications involving single dwellings with a metered service of 25mm and where that service is not supporting a fire support system do not require the rendition of a Consulting or Hydraulic Engineer's Report.

“Nominal” Sizing for charging purposes

Nominal sizing of meters will be conducted in the same fashion as downsizing. It is important that Council ensure compliance with the various building codes and firefighting requirements. Nominal sizing where fire services are involved will be limited to the level of connection needed for the property; were a fire service not installed. Nominal sizing of meters for other reasons (exceptional one-off) will require substantiation and will be considered on the merit.

Where approval is given for the nominal sizing of a service connection consequent to fire services being installed and where internal hose reels support that property, the nominal sizing will only remain if the hose reels are protected by lead security seals. Council will reserve the right to levy an availability charge based on the actual size of the connection if those seals are broken. Council will reserve the right to review the status of properties approved for nominal sizing.

The approved nominal sizing of meters will be contained and highlighted within Council's water billing system. The approved nominal sizing is subject to review and change by Council.

Costs

The responsibility for costs in respect of the policy are as follows:

- Costs to undertake disconnection or nominal sizing of meters will be borne by Council,
- Costs to undertake the downsize or subsequent upsize of meters will be at the applicants expense,

(The costs to supply and undertake the necessary works will be provided as an estimate on application and will be payable before works are commenced. In the estimate of costs Council will allow for a credit based on the difference in the price of the current connected meter size against that of the new meter size. Council will reserve the right to re-use the replaced meter as required)

- Costs to provide Consulting Engineers on Hydraulic reports or other supporting documentation in respect of disconnection, nominal sizing, downsizing or upsizing, will be the responsibility of applicants.

4 IMPLEMENTATION

The Water Customer and Business Services Section of Shoalhaven Water has responsibility for implementing this policy.

5 REVIEW

This policy is to be reviewed by Shoalhaven Water 1st December, 2016

6 APPLICATION OF ESD PRINCIPLES

No ESD principals are applicable to this policy.

Appendix 1 – Flowchart for processing applications

TRIM Reference D04/95504

