



**NOTES:**

1. CONCRETE TO HAVE MIN. CRUSHING STRENGTH ( $f_{c0}$ ) OF 20 MPa AFTER 28 DAYS.
2. TOP OF BENCHING TO BE 1/3 OF OUTLET PIPE DIA.
3. 50 mm DIA. WEEPHOLES ARE TO BE PROVIDED EITHER SIDE OF INLET PIPES AT INVERT LEVEL OF PIPE TRENCH.
4. PROVIDE CLIMB IRONS AS DETAILED ON SD 113 FOR PITS DEEPER THAN 1200 mm.
5. ALL PITS TO BE PROVIDED WITH A LOCKING CLIP.
6. PIPE TRENCHES BACKFILLED WITH SAND SHALL HAVE 3 m OF SUBSOIL DRAIN PIPE IN BOTTOM OF TRENCH AND DRAINING INTO PIT.
7. FORTY EIGHT (48) HOURS NOTICE IS TO BE GIVEN PRIOR TO THE PLACING OF CONCRETE TO ALLOW FOR INSPECTION BY COUNCIL'S OFFICER.

Fig. D5 Misc. 2



SCALE 1/ N.T.S.

SUBDIVISION  
CODE

CITY OF SHOALHAVEN  
STANDARD KERB  
INLET PIT

ENGINEERING WORKS  
MANAGER

DRAWN C. FIESELER

CHECKED J. BLOH

PLAN REF. 263702

DATE 04.MAY 1984