



- NOTES:**
1. CONCRETE TO HAVE MIN. CRUSHING STRENGTH (f_{c0}) OF 20 MPa AFTER 28 DAYS.
 2. TOP OF BENCHING TO BE 1/3 OF OUTLET PIPE DIA.
 3. 50 mm DIA. WEEPHOLES ARE TO BE PROVIDED EITHER SIDE OF INLET PIPES AT INVERT LEVEL OF PIPE TRENCH.
 4. PROVIDE CLIMB IRONS AS DETAILED ON SD 113 FOR PITS DEEPER THAN 1200 mm.
 5. ALL PITS TO BE PROVIDED WITH A LOCKING CLIP.
 6. PIPE TRENCHES BACKFILLED WITH SAND SHALL HAVE 3 m OF SUBSOIL DRAIN PIPE IN BOTTOM OF TRENCH AND DRAINING INTO PIT.
 7. FOURTY EIGHT (48) HOURS NOTICE IS TO BE GIVEN PRIOR TO THE PLACING OF CONCRETE TO ALLOW FOR INSPECTION BY COUNCIL'S OFFICER.

Fig. D5 Misc. 2



SCALE 1/ N.T.S.

SUBDIVISION
CODE

CITY OF SHOALHAVEN
STANDARD KERB
INLET PIT

ENGINEERING WORKS
MANAGER

DRAWN	C. FIESELER
CHECKED	J. BLOH
PLAN REF.	263702
DATE	04.MAY 1984