



- NOTES**
- FENCE DETAILS NOT SHOWN SHALL BE IN ACCORDANCE WITH AS 1725.
 - ALL FITTINGS TO BE HOT DIP GALVANIZED TO AS 4680.
 - ALL FASTENERS TO BE HOT DIP GALVANISED TO AS 1214.
 - JOINTS TO BE FULL SEAL WELDS IN ACCORDANCE WITH AS 1554 PART 1 STRUCTURAL STEEL WELDING CODE - WELDING OF STEEL STRUCTURES.
 - CONCRETE FOOTING MIN GRADE N20 CONCRETE. FOOTINGS MAY BE EITHER SQUARE OR CIRCULAR.
 - FIELD COATING REPAIR - DAMAGED COATING TO BE THOROUGHLY WIRE BRUSHED AND TREATED WITH TWO COATS OF DIMET ZINC RICH PAINT No. 10 OR APPROVED EQUIVALENT, OVERLAPPING ORIGINAL COATING.
 - FOLLOW MANUFACTURERS RECOMMENDED INSTALLATIONS INSTRUCTIONS
 - MAINTAIN UNIFORMITY OF EQUIPMENT UNLESS OTHERWISE NOTED
 - ALL EQUIPMENT IS TO BE NEW UNLESS OTHERWISE NOTED.
 - THE 300MM BURIED SELVEDGE IS TYPICALLY NOT REQUIRED, AND SHALL ONLY BE USED WHERE SPECIFICALLY REQUESTED. WHERE NOT REQUIRED, CONCRETE SUPPORT BLOCKS ARE TO BE RAISED TO GROUND LEVEL.

MATERIALS SCHEDULE		
ITEM	SIZE	DESCRIPTION
CHAINWIRE	2100 HIGH x 50 MESH x ϕ 3.15 BARBED TOP SELVEDGE	HEAVILY GALVANIZED WIRE WITH BLACK PLASTIC COATING
DOUBLE GATES	OUTER FRAME	25NB x 3.2 THICK
	INNER FRAME	20NB x 2.6 THICK
SINGLE GATES	OUTER FRAME	20NB x 2.6 THICK
	INNER FRAME	15NB x 2.6 THICK
GATE DIAGONAL BRACE	10NB x 2.3 THICK	M.G. STEEL PIPES TO A.S. 1074
CORNER, GATE AND SIDE STAYS	32NB x 3.2 THICK	M.G. STEEL PIPES TO A.S. 1074
INTERMEDIATE POST - TYPE 'A'	80NB x 4.0 THICK	M.G. STEEL PIPES TO A.S. 1074
INTERMEDIATE POST - TYPE 'B'	40NB x 3.2 THICK	M.G. STEEL PIPES TO A.S. 1074
CORNER, GATE AND END POSTS	80NB x 4.0 THICK	M.G. STEEL PIPES TO A.S. 1074

No.	REVISION DETAILS	AG	AG	MK	DATE
0	APPROVED ISSUE				04/02/2020

CONSULTANT DETAILS:					
CONSULTANT REFERENCE No. G-20855-016					

Shoalhaven Water
A Group of Shoalhaven City Council

DESIGNED: A. GALEA	DATE: 04/02/2020	COMPANY: SW	TITLE: SHOALHAVEN WATER STANDARD DRAWING SITE SECURITY CHAINLINK FENCING DRAWING		
DRAWN: A. GALEA	DATE: 04/02/2020	COMPANY: SW	SIZE: A1	SCALE: 1:25	INDEX No. G
CHECKED: A. GALEA	DATE: 04/02/2020	COMPANY: SW	DRAWING No. 20855	SHEET 016	REV No. 0
APPROVED: M. KIDD	DATE: 04/02/2020	COMPANY: SW			