



Licensee: Shoalhaven City Council, Shoalhaven Water, PO Box 42 Nowra 2541

Environmental Protection License No. 12357

EPA ID No. 9,10,11,12,13,14

Conjola Regional Sewage Scheme - Boreholes - Monitoring Summary

Borehole	Frequency	Date Sample Obtained	Date Result Obtained	Analyte						
				BOD (mg/L)	Chlorine (Total Residual) (mg/L)	Faecal Coliforms (CFU/100mL)	Nitrogen (Total) (mg/L)	Phosphorus (Total) (mg/L)	Depth To Water (m)	Standing Water Level (m AHD)
MB2S (E-760) EPA ID 9	Quarterly	23-Jul-25	31-Jul-25	<2	0.06	<1	3.2	0.12	11.00	0.83
MW8S (E-782) EPA ID 10	Quarterly	23-Jul-25	31-Jul-25	Dry	Dry	Dry	Dry	Dry	Dry	Dry
D02 R (E-758) EPA ID 12	Quarterly	23-Jul-25	31-Jul-25	5	0.11	2	6.8	4.84	6.54	1.81
D03 R (E-759) EPA ID 11	Quarterly	23-Jul-25	31-Jul-25	4	0.00	<1	2.6	1.18	7.11	1.62
MB5 (E-716) EPA ID 13	Quarterly	23-Jul-25	31-Jul-25	4	0.35	<1	3.3	0.12	1.24	1.57
V5 (E-715) EPA ID 14	Quarterly	23-Jul-25	31-Jul-25	3	0.47	<1	2.6	0.07	1.23	1.18

NOTES:

Full list of borehole data can be found on Aqua Data.

*<0.20 = LOR reduced due to dirty sample

R = Replacement borehole.

NR= No Result due to water colour, dry borehole or borehole requiring re-development.